

Environmental Certification Scheme



Carpet Name: GA SERIES

Licensee: NOLAN.UDA P/L
Licence Number: 1307
Label Number: 13119

Certification Approved:

Level: 3

ACCS Contract Grading: CEHD 4*
ACCS Residential Grading: REHD2 6*
Suitable for Stairs: Yes

Date Printed: 31/10/2013

Allan Firth



Allan Firth
Secretary ACCS



Administered by the Carpet Institute of Australia Limited ABN 11 006 829 303
PO Box 7172, St Kilda Road, Melbourne Victoria 8004 Tel: (03) 9804 5559 • Fax: (03) 9804 5560
Email: info@carpetoz.com.au • www.carpetinstitute.com.au

This certificate remains the property of the Carpet Institute of Australia Limited.

Carpet Details:

Company: NOLAN.UDA P/L

Licence No: 1307

Office No: 5700

Label No: 13119

Names:

GA SERIES

Details:

Awarded Res Grade: REHD2 6*
 Awarded Con Grade: CEHD 4*
 Registered On: 30/07/2013
 Active: Yes
 Date In-Active:
 Manufacture Method: Tufted
 Twist Set: N/A
 Dyeing Method: Piece Dyed
 #Colours/Designs: 8
 Backing Type: PVC
 Felted: N/A
 Spinning System: BCF
 Insect Resist Agent: N/A
 Master Product:

Test Results:

Pile Mass g/m² (oz/yd²): 590 (17.4)
 SPM g/m² (oz/yd²): 473 (14.0)
 Stated Pile Height (mm): 3.0
 Minimum Pile Height (mm): 2.5
 Maximum Pile Height (mm): 3.5
 Dynamic Loading Loss (%): 9.1
 Static Loading Loss (%): 6.1
 Tex (g/1000m): 277
 Measured Pile Thickness (mm): 3.3
 Machine Gauge (Tufts/dm): 47.0
 Meas Tufts Perp to Selvedge: 40.1
 Meas Tufts Para to Selvedge: 47.5
 Treated For Soiling Resistance: Yes
 Flouro Carbon Treated: Yes
 Stain Resist Chem Treated: No

Hexapod Scores:

	Text Chng	Wrst Angl	Col Chng	Wrst Angl	Loss (mm)	Loss (%)
1500:	4.5	4.5	4.5	4.5	0.2	6.1
8000:	3.5	4.0	3.0	4.0	0.6	18.2

Quality Assurance Test:

Cut Pile (%): 0
 Loop Pile (%): 100
 Panel Assessment Contract: 15
 Panel Assessment Residential: 15
 Suitable For Stairs: Yes
 Tile: Yes SheetGoods: No
 Fibre Signature: NBA:100

ACCS Test:

	Con	Res	Max
SPM/PH Ratio:	16	16	16
Volume Density:	16.5	16.5	20
Tuft Density:	9	9	9
Dyn Load:	5	5	5
Stat Load:	5	5	5
Soiling Prop:	13	13	16
Abraison Res:	10	10	10
Sub Total:	74.5	74.5	81
Panel Assess:	15	15	19
Total:	89.5	89.5	100
Calc Residential Grade:	REHD2	6*	
Calc Contract Grade:	CHD	3*	

Calculations

Pile Height(mm): 3.8
 Tuft Density(per dm²): 1904.8
 GSPM(g/m²): 397.0
 GSPM (abrasive) (g/m²): 275.0
 Soiling Propensity: 12.0 +1.0

OAF Values

OAF: 3.9
 Calc Density (+-5%): 0.14 0.143 0.15
 Base Fibre: NYLON
 Benchmarks:
 RHD1 0 RHD2 3.5
 REHD1 3.5 REHD2 3.5

Environmental Classification:

ECS: Yes
 Level: 3

	Calc	B/M	P/F
Acoustic:	3.3	3	PASS
Thermal:	23	15	PASS
VOC:			
TVOC	104		

Notes:

31/07/13 Submitted by S. Gilbertson. 31/7/13 Panel awarded REHD2(S) 6* and CEHD(S) 4*. 30/10/13 Panel certified ECS Level 3.