



Infrastructure Technologies

Gate 5, 2 Normanby Road Clayton VIC 3168, Australia

Telephone: 61 3 9545 2777 Web: <http://www.csiro.au>

Registered Testing Authority - CSIRO

2 September 2020

Our Ref. EN13 / 2410 03/0212

TEST REPORT No. 8345.2

Requested by: Nolan.UDA Pty. Ltd.
3 Bradford Street
Alexandria
NSW 2015

on (date): 30 July 2020

Manufacturer: Imported

Product Desc.: Raider, PP carpet with Latex coating at back.
400mm x 300mm x 6.3mm

Sampling details:

Where: At customer premises

Date: 4 August 2020

By whom: Client (delivered by courier)

How (methods): N/A

The results reported relate only to the sample(s) tested and the information received. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. CSIRO cannot accept responsibility for deviations in the manufactured quality and performance of the product. While CSIRO takes care in preparing the reports it provides to clients, it does not warrant that the information in this particular report will be free of errors or omissions or that it will be suitable for the client's purposes. CSIRO will not be responsible for the results of any actions taken by the client or any other person on the basis of the information contained in the report or any opinions expressed in it. The reproduction of this test report is only authorised in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction.

This test report consists of 4 pages

SUMMARY OF SLIP RESISTANCE TESTS PERFORMED:

		Result	Class
AS 4586:2013	Slip resistance classification of new pedestrian surface materials Appendix A: WET PENDULUM TEST METHOD (Slider 96): Mean SRV:	71	P5

In order to interpret the classifications, please refer to Standards Australia Handbook 198, An Introductory Guide to the Slip Resistance of Pedestrian Surface Materials, which recommends minimum classifications for a wide variety of locations.

It is important to realise that test results obtained on unused factory-fresh samples may not be directly applicable in service, where proprietary surface coatings, contamination, wear and subsequent cleaning all influence the behaviour of the pedestrian surface.



REPORT NO: 8345.2
ISSUE DATE: 2 September 2020
MANUFACTURER: Imported
PRODUCT DESC: Raider, PP carpet with Latex coating at back.
400mm x 300mm x 6.3mm

PHOTOS:



Top view



Close up



REPORT NO: 8345.2
ISSUE DATE: 2 September 2020
MANUFACTURER: Imported
PRODUCT DESC: Raider, PP carpet with Latex coating at back.
400mm x 300mm x 6.3mm

SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS

WET PENDULUM TEST METHOD

TEST CARRIED OUT IN ACCORDANCE WITH
AS 4586:2013 (Appendix A)

Test Date: 2 September 2020

RESULTS:	Location:	Slip Resistance Laboratory	Slider used: 96
	Sample:	Unfixed	Conditioned with grade P400 paper, dry
	Cleaning:	Dry el/static cloth	and Imperial Lapping Film Grade 3MIC, wet
	Temperature:	22.2°C	

Pendulum Friction Tester: ERM 030.040 (S/N: 1726, calibrated 20/09/19), S 96 serial #: 94 (expired on 13/11/2020)
Test conducted by: Khanh Ho

	Specimen				
	1	2	3	4	5
Last 3 swings (BPN)	69	72	71	72	71
	68	72	71	72	71
	68	72	71	72	71
Averages	68	72	71	72	71

Mean SRV : 71

CLASS :

P5

Comments:
Surface Tested Dry



Infrastructure Technologies

Gate 5, 2 Normanby Road Clayton VIC 3168, Australia

Telephone: 61 3 9545 2777 Web: <http://www.csiro.au>

REPORT NO: 8345.2
ISSUE DATE: 2 September 2020
MANUFACTURER: Imported
PRODUCT DESC: Raider, PP carpet with Latex coating at back.
400mm x 300mm x 6.3mm

Page 4 of 4

Date and Place 2 September 2020, Clayton, Vic

Name, Title and Digital Signature:

A digital signature in black ink, appearing as a stylized cursive script, overlaid on a semi-transparent circular watermark of the CSIRO logo.

KHANH HO
Technical Officer
Tel: 61 3 95452777
Email: Khanh.Ho@csiro.au