

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400


TEST REPORT

Client : Nolan UDA 3 Bradford S Alexandria N	Street		lssue Print	Number : • Date : Date : r Number :	21-00014 12/03/202 12/03/202 210107	21		
Sample Description	Clients Ref : "Kachi Random" Loop pile carpet tile Colour : Charcoal End Use : Flooring Nominal Composition : Nylon v Nominal Mass per Unit Area/Dens Nominal Thickness : 6.5mm	-						
ISO 9239.1-2003	Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source							
	Date of Sample Arrival 15-01-2021							
	Date Tested 11-03-2021							
	CHF Value	1	2	3	Mean			
	Length	2.4	-	-	-	kW/m²		
	Width	2.3	3.2	2.7	2.7	kW/m²		
	HF-30 Value	1	2	3	Mean			
	Length	4.4	-	-	-	kW/m²		
	Width	4.4	5.1	4.4	4.6	kW/m²		
	Smoke Value	1	2	3	Mean			
	Length	326	-	-	-	%.min		
	Width	323	324	278	308	%.min		
	Melting				Yes			

230869

49185

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



NATA

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

SADM

Page 1 of 2



MICHAEL A. JACKSON B.Sc.(Hons)

Sean Bassett



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client :	Nolan UDA Pty Ltd	Test Number	:	21-000147
	3 Bradford Street	Issue Date	:	12/03/2021
	Alexandria NSW 2015	Print Date	:	12/03/2021
		Order Number :		210107

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

230869

49185

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

SADM

Sean Bassett



Page 2 of 2



C