## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## **TEST REPORT**

Client: Nolan UDA Pty Ltd

3 Bradford Street
Alexandria NSW 2015

**Test Number** : 21-001356

**Issue Date** : 10/05/2021 **Print Date** : 10/05/2021

210316

Order Number:

**Sample Description** 

Clients Ref : "Supacord Tile"

Loop pile carpet tile
Colour: Charcoal
End Use: Flooring

Nominal Composition: 80% Polypropylene, 15% Nylon, 5% Blended Polyester, bitumen backing

Nominal Mass per Unit Area/Density: 4020g/m2

AS ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

**Radiant Heat Source** 

Date of Sample Arrival

19-03-2021

Date Tested

07-05-2021

CHF Value	1	2	3	Mean	
Length	3.7	-	-	-	kW/m²
Width	3.6	3.6	3.6	3.6	kW/m²
HF-30 Value	1	2	3	Mean	
Length	3.7	-	-	-	kW/m²
Width	3.6	3.6	3.6	3.6	kW/m²
Smoke Value	1	2	3	Mean	
Length	307	-	-	-	%.min
Width	335	326	381	347	%.min

Melting Yes

236642 50496 Page 1 of 2

 Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Figna McDonald

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc.(Hons)

## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## **TEST REPORT**

Client: Nolan UDA Pty Ltd

3 Bradford Street Alexandria NSW 2015 **Test Number** : 21-001356

**Issue Date** : 10/05/2021 **Print Date** : 10/05/2021

210316

Order Number:

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

236642 50496 Page 2 of 2

 Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Fiona McDonald

MICHAEL A. JACKSON B.Sc.(Hons)